

ADDENDUM TO:

2005

Annual Drinking Water Quality Report of the City of Longwood

The following information was inadvertently omitted from the chart on page 3 in the section labeled Trihalomethanes.

For the following parameters monitored under Stage 1 D/DBP regulations, the level detected is the annual average of the quarterly averages: Bromate, Chloramines, Chlorine, Haloacetic Acids, and/or TTHM (MCL 80 ppb). Range of Results is the range of results (lowest to highest) at the individual sampling sites.

| Contaminant and Unit of Measurement | Date of sample analysis | MCL Violation Y/N | Level Detected | Range of Results | MCLG | MCL | Likely Source of Contamination |
|-------------------------------------|-------------------------|-------------------|----------------|------------------|-----------|------------|-----------------------------------------|
| Chlorine (ppm) | Jan-Dec 2005 | N | 1.8 | 0.4 - 5.0 | MRDLG = 4 | MRDL = 4.0 | Water additive used to control microbes |