

# 2003

## Annual Drinking Water Quality Report of the City of Longwood

This is an annual report on the quality of water delivered by the City of Longwood. It meets the federal Safe Drinking Water Act (SDWA) requirement for "Consumer Confidence Reports" and contains information on the source of our water, its constituents, and the health risks associated with any contaminants. Safe water is vital to our community. Please read this report carefully and, if you have questions, call the numbers listed below.

We encourage public interest and participation in our community's decisions affecting drinking water. Regular City Commission meetings occur on the 1st and 3rd Mondays of each month, at the City Hall Commission Chambers located at 175 West Warren Avenue. The public is welcome. We'll be happy to answer any questions about the City of Longwood water system and our water quality. Call Richard Kornbluh at 407-263-2388.

More information is available on the World Wide Web at <http://www.ci.longwood.fl.us>

### Overview

#### Water Source and Treatment

What is the source of our water? Five wells at a depth of 300 to 500 feet in the City of Longwood supply our system with groundwater of high purity. Our water is then chlorinated for disinfection purposes and fluoridated for dental health purposes.

#### An Explanation of the Water-Quality Data Table

This report is based upon tests conducted between January 1 and December 31 in the year 2003 by the City of Longwood. The data presented in this report is from the most recent testing done in accordance with regulations. Terms used in the Water-Quality Table and in other parts of this report are defined here.

**Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Action Level (AL):** The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (µg/l)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Not Applicable (N/A)** - does not apply.

### Key To Table

AL = Action Level

MCL = Maximum Contaminant Level

MCLG = Maximum Contaminant Level Goal

pci/l = picocuries per liter (a measure of radioactivity)

ppm = parts per million, or milligrams per liter (mg/l)

ppb = parts per billion, or micrograms per liter (µg/l)

ND= Non-Detects

N/A= Not Applicable

**TEST RESULTS TABLE**

| <b>Contaminant and Unit of Measurement</b> | <b>Date of sample analysis</b> | <b>MCL Violation Y/N</b> | <b>Highest Monthly Number</b>                        | <b>Range</b>  | <b>MCLG</b> | <b>MCL</b>                                                                                                 | <b>Likely Source of Contamination</b>                                                                                     |
|--------------------------------------------|--------------------------------|--------------------------|------------------------------------------------------|---------------|-------------|------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------|
| <b><i>Microbiological Contaminants</i></b> |                                |                          |                                                      |               |             |                                                                                                            |                                                                                                                           |
| Total Coliform Bacteria                    | 2003                           | No                       | 0                                                    | N/A           | 0           | Presence of coliform bacteria in 1 sample collected during a month.                                        | Naturally present in the environment                                                                                      |
| <b>Contaminant and Unit of Measurement</b> | <b>Date of sample analysis</b> | <b>MCL Violation Y/N</b> | <b>Total Number of Positive Samples for the Year</b> | <b>Range</b>  | <b>MCLG</b> | <b>MCL</b>                                                                                                 | <b>Likely Source of Contamination</b>                                                                                     |
| Fecal coliform and <i>E.coli</i>           | 2003                           | No                       | 0                                                    | N/A           | 0           | A routine sample is fecal coliform positive or <i>E. coli</i> positive and the repeat samples are negative | Human and animal fecal waste                                                                                              |
| <b>Contaminant and Unit of Measurement</b> | <b>Date of sample analysis</b> | <b>MCL Violation Y/N</b> | <b>Level Detected</b>                                | <b>Range</b>  | <b>MCLG</b> | <b>MCL</b>                                                                                                 | <b>Likely Source of Contamination</b>                                                                                     |
| <b><i>Radiological Contaminants</i></b>    |                                |                          |                                                      |               |             |                                                                                                            |                                                                                                                           |
| Gross Alpha (pCi/l)                        | 12/2002                        | No                       | 0.9                                                  | 0.6-0.9       | 0           | 15                                                                                                         | Erosion of natural deposits                                                                                               |
| <b><i>Inorganic Contaminants</i></b>       |                                |                          |                                                      |               |             |                                                                                                            |                                                                                                                           |
| Barium (ppm)                               | 05/2002                        | No                       | 0.0093                                               | 0.0068-0.0093 | 2           | 2                                                                                                          | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                                |
| Chromium (ppb)                             | 05/2002                        | No                       | 5.6                                                  | 4.5-5.6       | 100         | 100                                                                                                        | Discharge from steel and pulp mills; erosion of natural deposits                                                          |
| Fluoride (ppm)                             | 05/2002                        | No                       | 1.06                                                 | 0.314-1.06    | 4           | 4                                                                                                          | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Lead (point of entry) (ppb)                | 05/2002                        | No                       | 1.8                                                  | ND-1.8        | N/A         | 15                                                                                                         | Residue from man-made pollution such as auto emissions and paint.; lead pipe, casing, and solder                          |
| Nickel (ppb)                               | 05/2002                        | No                       | 3.2                                                  | 2.4-3.2       | N/A         | 100                                                                                                        | Pollution from mining and refining operations. Natural occurrence in soil.                                                |
| Selenium (ppb)                             | 05/2002                        | No                       | 2.3                                                  | ND-2.3        | 50          | 50                                                                                                         | Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines                          |
| Sodium (ppm)                               | 05/2002                        | No                       | 19.9                                                 | 11.4-19.9     | N/A         | 160                                                                                                        | Salt water intrusion, leaching from soil                                                                                  |

| Contaminant and Unit of Measurement       | Date of sample analysis | AL Exceeded Y/N   | 90th Percentile Result             | No. of sampling sites exceeding the AL | MCLG | AL (Action Level) | Likely Source of Contamination                                                                         |
|-------------------------------------------|-------------------------|-------------------|------------------------------------|----------------------------------------|------|-------------------|--------------------------------------------------------------------------------------------------------|
| <b><i>Lead and Copper (Tap Water)</i></b> |                         |                   |                                    |                                        |      |                   |                                                                                                        |
| Lead (tap water) (ppb)                    | 2003                    | No                | 2.0                                | One sampling site exceeded AL          | 0    | AL=15             | Corrosion of household plumbing systems, erosion of natural deposits                                   |
| Copper (tap water) (ppm)                  | 2003                    | No                | 0.449                              | No sampling site exceeded AL           | 1.3  | AL=1.3            | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| Contaminant and Unit of Measurement       | Date of sample analysis | MCL Violation Y/N | Level Detected                     | Range of Results                       | MCLG | MCL               | Likely Source of Contamination                                                                         |
| <b><i>Trihalomethanes</i></b>             |                         |                   |                                    |                                        |      |                   |                                                                                                        |
| TTHM [Total trihalomethanes] (ppb)        | 2003                    | No                | 36.2 (annual average) <sup>1</sup> | 23.7 – 93.9                            | 0    | 100               | By-product of drinking water chlorination                                                              |

### Water-Quality Table Footnotes

<sup>1</sup> This number is based on an average of 16 samples in 2003 which ranged from 23.7 to 93.9 ppb.

### Explanation of Violations

We failed to complete required sampling for routine bacteriological sampling for total coliform in the last week of December 2003 and therefore were in violation of monitoring and reporting requirements. Because we did not take the required number of samples, we did not know whether the contaminants were present in your drinking water, and we are unable to tell you whether your health was at risk during that time. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. The monitoring period was 12/1/03 through 12/31/03. Twenty samples were required for the monitoring period and sixteen were collected. Sampling resumed on 1/1/04.

We failed to meet the reporting requirements for the 2002 CCR by failing to submit a copy of the CCR by July 1, 2003 to the Florida Department of Environmental Protection along with the mailing to our customers. A copy of the report was submitted on July 29, 2003 along with the certification of delivery prior to August 10, 2003 as required. This violation has no impact on the quality of the water our customers received, and it posed no risk to public health. We have established a report tracking file to ensure that all reporting requirements are met in the future.

## Required Additional Health Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (D) *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- (E) *Radioactive contaminants*, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

**Some people may be more vulnerable to contaminants in drinking water than is the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline 800-426-4791.**

## Other Monitoring

In addition to testing we are required to perform, our water system voluntarily tests for hundreds of additional substances and microscopic organisms to make certain our water is safe and of high quality. We'll be happy to answer any questions about the City of Longwood water system and our water quality. If you are interested in a more detailed report, contact Richard Kornbluh at 407-263-2388.

This report was prepared using CCRbuilder and technical assistance provided by the American Water Works Association, the Florida Rural Water Association and the Florida Department of Environmental Protection.

Water Quality Data for community water systems throughout the United States is available at [www.waterdata.com](http://www.waterdata.com).